

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-19-08-22-02

**Products:** Quick Step Rigid 5mm-CL32 + Quick Step Rigid 5mm-CL33  
Thickness: 5 mm  
Underlay: 1-2 mm PE underlay

**Producer:** Mohawk – division flooring Belgium, Nijverheidslaan 29, 8580 Avelgem, Belgium

**Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)

**Test reports:** 2718282 / 19-0555-01

**Test results:**

Property	Results	Declaration according to EN 14041:2008
Reaction to fire according to EN ISO 9239-1:2010 and EN ISO 11925-2:2011; Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	9.7 kW / m <sup>2</sup> 312 % * min	B <sub>fl</sub> -s1
Anti-sliding properties according to EN 13893:2003	μ = 0.51	class DS
Thermal resistance according to EN 12667:2001	0.0166 (m <sup>2</sup> K)/W	0.02 (m <sup>2</sup> K)/W
Content of PCP according to CEN/TR 14823:2004	Not detected	PCP < 5 ppm

Dresden, 22/08/2019



Head of laboratory




Engineer in charge