



Entwicklungs- und Prüflabor  
Holztechnologie GmbH  
Zellescher Weg 24 · D-01217 Dresden  
www.eph-dresden.de



Deutsche  
Akkreditierungsstelle  
D-PL-11054-01-00  
D-ZE-11054-01-00

accredited by Deutsche Akkreditierungsstelle GmbH (DAkkS)

Deutsches  
Institut  
für  
Bautechnik



European Notified Body for construction products 0766  
Recognized body of DIBt SAC03

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-13-09-03-10

**Product:** Cork Flooring Glue-down with UV high resistance varnish surface, thickness: 4 mm

**Producer:** Amorim Revestimentos, S.A.  
Rua do Ribeirinho, 202 (Apartado 13)  
4536-907 S. Paio de Oleiros  
Portugal

**Order:** Testing and classification of selected properties according to EN 14041  
(CE-labelling)

**Test report:** 2713168

**Test results:**

Property	Declaration according to EN 14041
Fire resistance according to EN 9239-1 and EN ISO 11925-2. Classification according to EN 13501-1	D <sub>fl</sub> -s1
Anti-sliding properties according to EN 13893	class DS
Formaldehyde emission according to EN 717-1	class E1
Content of PCP according to CEN/TR 14823	not to declare
Thermal resistance according to EN 12667	0.05 (m <sup>2</sup> K)/W

Dresden, September 03<sup>rd</sup> 2013



*R. Aule*

Head of laboratory

*J. J. K.*

Engineer in charge